

STATE OF WEST VIRGINIA

INSPECTION TO BE PRINTED OR TYPED

Mineral County HEALTH DEPARTMENT

Permit No.: ST-029 - 09 - 013

Tax Map: 41 Parcel #: 61

County: Mineral

ON-SITE SEWAGE DISPOSAL SYSTEM INSPECTION FORM

County Road:

Name of Owner: Michael & Cindy Shreve Installer: Cabin Run Contracting

Address: P.O. Box 760, Fort Ashby, WV 26719

Property Location: Rt 46 to Foreback Rd, Go to end of terr. chip, just down over hill, turn up

Type of Facility: Residence Facility is: New (X) Existing () Lot Size: 19.52 Sq. Ft./Acres

Design Loading in gpd/No. Bedrooms: 5 BR's Source of Water Supply: Private (Not installed yet)

SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: Concrete Manufacturer: Pyles

Distances (in feet) of Tank to: Dwelling: 56' Private (X)/Public () Water Source: N/A Property Line: 100'

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Absorption Trenches () or Bed () Gravelless Pipe (), Diameter: ___ Inches Chamber Soil Absorption Trenches (X) or Bed ()

Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed () Evapotranspiration Trenches () or Bed () Shallow Soil Absorption Trenches () or Bed () Other: _____

No. of Lines: 5 Length (in feet) of Each: 80, 80, 80, 80, 80

Width of Trenches: 36 inches/feet Depth to Bottom of Field: 24-28 inches

If Bed, Dimensions (in Feet): If Chamber System, Name: No. of Units:

Approved and Adequate Materials Used? Yes (X) No () Size Equates to: 2000 Square Feet of Standard Gravel Field.

Distances (in feet) of System to: Dwelling: 75' Private (X)/Public () Water Source: N/A Property Line: 100'

Remarks: System was installed correctly w/ A-Box on pad w/ speed levelers. N=39° 28' 9.6" W=78° 49' 21.0"

An inspection indicates that the sewage disposal system described above DOES MEET (), DOES NOT MEET (), CANNOT BE DETERMINED TO MEET () the minimum standards established by the West Virginia Bureau of Public Health.

To correct a health hazard, modifications to existing systems may be done to improve part of a system. Such modifications may not be able to be designated as a does meet system since inadequate information is known.

Although many factors contribute to the successful functioning of a sewage disposal system, this office recommends water conservation and maintaining an even usage of water throughout the week.

Sketch of Installation with Triangulation or Distance to Specific Landmarks: See attached drawing. Includes a circle and the instruction 'Draw Arrow toward North'.

Visit Date(s): 1-20-09

Final Inspection Date: 1-20-09

Sanitarian: [Signature] R.S.

