

Lot 15

### REQUEST FOR SITE APPROVAL

To: **Hardy County Health Department, Moorefield, WV**

From: Name: Melbourne Prop. / Phone 856-2957  
Address P.O. Box 507 Capon Bridge WV 26711

RE: Property Location Lost River / on Whetzel Rd.

Request is hereby made for a site investigation to determine the suitability of the subject property as a site for small sewage system indicated below:

Septic System     Pit Privy     Vault Privy     Other

The results of a percolation test conducted in accordance with the requirements of Design Standards for Small Septic Tank Systems follows:

Depth of test holes: #1 24, #2 \_\_\_\_\_, #3 \_\_\_\_\_, #4 \_\_\_\_\_ inches.

Time for water to fall 6 inches in test hole	#1	<u>240</u>	minutes
	#2	<u>180</u>	minutes
	#3	<u>180</u>	minutes
	#4	<u>240</u>	minutes
	Total	<u>35</u>	minutes.

400 sq ft  
for  
Bedroom

A test hole bored or dug 6 feet deep  has  has not been provided to help determine the depth to bedrock and ground water table.

On the back of this form a plot layout has been sketched showing the property lines and relative locations of buildings, water supplies, percolation test holes, six ft. hole, and other pertinent features.

I (we), the undersigned, certify that the information contained herein is correct and accurate to the best of my (our) knowledge. It is further understood that this form is not an application for a permit, and subsequent acceptance of this site by the designed health department does not constitute a permit to install a sewage system.

X Owner's Signature Deirda L. Stratten Date 6/13/05

Percolation test conducted by: Name: Meadie's Special Services  
Address: P.O. Box 188, Capon Bridge WV 26711

Date: 6/6/05 / Signature Wendell Meade

**For Health Department Use Only**

This is to certify that the Hardy County Health Department reviewed the contents of this form and conducted a site visit on subject property. Based on the information provided it is the opinion of the undersigned that this site  is  is not Suitable for the installation of the small sewage system indicated.

Signature and Title Will Ours Sond Date 6/6/05