



## Hampshire County Health Department

HC 71, Box 9

Augusta, WV 26704

Nursing: (304) 496-9640 Environmental: (304) 496-9641

Fax: (304) 496-9650

December 22, 2006

Hampshire County Planning Commission  
PO Box 883  
Romney, WV 26757

Dear Sirs:

This office has reviewed a plat of survey for WV Hunter, LLC to approve a subdivision called Bluffs on the Potomac Section 6 located on Graces Cabin Road, and further referenced as Tax District Romney, Tax Map 33, Parcel 3, Deed book 436, Page 638. This subdivision section consists of 39 lots containing 823.22 acres. All lots contain a sewage disposal area of 10,000 square feet where no development or structures other than the septic system shall be permitted. These lots are to be developed with individual wells and septic systems to serve single family dwellings.

Percolation test results are within limits as set forth by West Virginia CRS 16-1. Six foot soil observation holes indicate no restrictions due to water table or shallow bedrock within the designated sewage disposal area except as noted on the Health Department subdivision application.

The plat of survey dated 10/16/06, is hereby approved by the Hampshire County Health Department. Any changes or revisions to the Health Department stamped and signed plat, or subsequent final plats approved based upon the approved plat, will make this approval null and void.


This approval is not permit for individual water systems or individual sewer systems. Applications for permits must be made separately to the Hampshire County Health Department.

Sincerely,

A handwritten signature in cursive script, appearing to read "Terry Mayhew".

Terry Mayhew, RS

CC: WV Hunter, LLC



Section 6

**REPORT SHEET  
FOR  
PERCOLATION AND SIX FOOT HOLE TESTING**

Subdivision Name Bluffs on The Potomac County Hampshire

Total Number of Lots 39 (Sect 6) Name of Applicant WV Hunter LLC

Name of Certified Installer Responsible for Testing Justin Time Etc.

Installer Certification No. 5400-A-0207 Installer Signature Darryl Mullins

Address Hc 164 Box 1634 Romney WV 26257

Type System	Lot Number	Percolation Test Results (Minutes per Inch of Fall)					Average Results	Six Foot Hole Results		Date Conducted
								Depth to Water	Depth to Rock	
I	145	120	85	90	108	16.7	N/A	N/A	4-15-06	
II	146	110	120	80	100	17.00				
II	147	85	125	130	110	18.7				
II	148	90	85	100	135	17.0				
II	149	120	125	135	65	17.7				
II	150	100	110	65	95	15.4				
I	151	65	125	85	50	13.5				
II	152	130	65	45	50	12.0				
II	153	85	120	90	100	16.4				
II	154	120	85	125	55	15.2				
II	155	105	50	100	65	13.3				
I	156	120	85	100	95	16.6				
II	157	125	85	65	140	17.2				
I	158	135	108	120	117	20.8				
I	159	85	105	120	100	17.0				
I	160	90	105	98	100	16.3				
I	161	100	65	185	55	16.8				
I	162	111	117	95	105	17.8				
I	163	58	98	78	100	13.9				
I	164	135	110	125	140	21.2				

(Attach additional pages if needed)

1026

**REPORT SHEET  
FOR  
PERCOLATION AND SIX FOOT HOLE TESTING**

Subdivision Name Bluffs on the Potomac County Hampshire

Total Number of Lots \_\_\_\_\_ Name of Applicant \_\_\_\_\_

Name of Certified Installer Responsible for Testing Justin Time Exc.

Installer Certification No. 54-00-A-0207 Installer Signature Mary Mullins

Address HC 64 Box 1634 Romney, W.V. 26757

Type System	Lot Number	Percolation Test Results (Minutes per Inch of Fall)					Average Results	Six Foot Hole Results		Date Conducted
								Depth to Water	Depth to Rock	
II	165	130	80	150	112	19.6				
I	166	120	85	117	141	19.2				
I	167	135	111	180	110	22.3				
I	168	112	125	116	100	18.8				
I	169	120	116	135	95	19.4				
II	170	145	90	100	110	18.5				
<del>II</del>	<del>171</del>	<del>85</del>	<del>86</del>	<del>105</del>	<del>117</del>	<del>16.7</del>	See Attached	Page Report		
II	172	110	118	150	140	21.5				
II	173	85	145	100	138	19.5				
II	174	140	120	135	112	21.1				
I	175	145	155	165	130	24.7				
II	176	180	180	176	145	28.3				
I	177	85	140	130	165	21.6				
II	178	100	150	122	145	21.5				
II	179	65	85	100	40	12.8				
II	180	90	85	115	100	16.2				
II	181	155	148	170	85	23.2				
#	182	160	135	112	122	22.0				
II	183	65	90	119	130	16.8				

(Attach additional pages if needed)