

## STATE OF WEST VIRGINIA

INSPECTION TO BE  
PRINTED OR TYPEDHardy County HEALTH DEPARTMENTON-SITE SEWAGE DISPOSAL SYSTEM  
INSPECTION FORMPermit No.: ST-16-05-002

Tax Map: \_\_\_\_\_ Parcel #: \_\_\_\_\_

County Road: \_\_\_\_\_

County: HardyName of Owner: Michael honey Installer: Billy HaetAddress: 102 EAST WAYNE AVE. Silver Spring Md 20901Property Location: lot 333 ASHTON WOODS, MCNEIL WVType of Facility: Home Facility is: New ☒ Existing ( ) Lot Size: 20.5 Sq. Ft. (Acres)Design Loading in gpd/No. Bedrooms: 3 Bdrm Source of Water Supply: Proposed well

## SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: CONCRETE Manufacturer: JolinDistances (in feet) of Tank to: Dwelling: 90 Private ☒/Public ( ) Water Source: 100' Property Line: \_\_\_\_\_

## ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Absorption Trenches ( ) or Bed ( ) Gravelless Pipe ( ), Diameter: \_\_\_\_\_ Inches  
Chamber Soil Absorption Trenches ☒ or Bed ( )Class II Systems: Pumped/Dosed Soil Absorption Trenches ( ) or Bed ( ) Evapotranspiration Trenches ( ) or Bed ( )  
Shallow Soil Absorption Trenches ( ) or Bed ( ) Other: \_\_\_\_\_No. of Lines: 3 Length (in feet) of Each: 80, 80, 80, \_\_\_\_\_, \_\_\_\_\_, \_\_\_\_\_Width of Trenches: 18-36 inches/feet Depth to Bottom of Field: 18-36 inchesIf Bed, Dimensions (in Feet): \_\_\_\_\_ If Chamber System, Name: INFILTRATORS, No. of Units: 60Approved and Adequate Materials Used? Yes ☒ No ( ) Size Equates to: 1200 Square Feet of Standard Gravel Field.Distances (in feet) of System to: Dwelling: 100' Private ☒/Public ( ) Water Source: 100' Property Line: \_\_\_\_\_

Remarks: \_\_\_\_\_

An inspection indicates that the sewage disposal system described above

DOES MEET ☒.

DOES NOT MEET ( ),

CANNOT BE DETERMINED TO MEET ( ) the minimum standards established by the West Virginia Bureau of Public Health.

To correct a health hazard, modifications to existing systems may be done to improve part of a system. Such modifications may not be able to be designated as a does meet system since inadequate information is known.

Although many factors contribute to the successful functioning of a sewage disposal system, this office recommends water conservation and maintaining an even usage of water throughout the week.

## Sketch of Installation with Triangulation or Distance to Specific Landmarks:

Drawing on Back.

Draw Arrow  
toward NorthVisit Date(s): 1-3-2005Final Inspection Date: 1-14-05Sanitarian: William Ows, Sanitar

⊗ Well Site

