

SUBDIVISION
Approved Lots Subject to Noted Modifications

Lot #	Lot Size Acre	Avg. Perc (Min.)	6' Excavation Observed	Reserve Area Location	Drainfield Design			Comments
					Depth	Sq. Ft. of Trench Area	Trench Separation	
38	20.18	7.4	Water at 4 feet	Platted	18"	300 sq. ft. per bedroom	standard	Class II - Low Pressure Dosing System
39	23.45	19.0	Good	Platted	18" to 24"	"	"	None
40	25.42	10.0	Good	Platted	18" to 24"	"	"	None
41	20.08	7.0	Water	Platted	18"	"	"	Class II - Low Pressure Dosing System
42	20.11	7.0	Good	Platted	18" to 24"	"	"	None
43	20.11	8.3	Good	Platted	18" to 24"	"	"	None
44	20.35	8.9	Good	Platted	18" to 24"	"	"	None
45	20.11	7.8	Water at 3 1/2 feet	Platted	18" to 24"	"	"	Curtain drain above field
46	20.21	13.6	Good	Platted	18" to 24"	"	"	None

SUBDIVISION
Approved Lots Subject to Noted Modifications

Lot #	Lot Size Acre	Avg. Perc (Min.)	6' Excavation Observed	Reserve Area Location	Drainfield Design			Comments
					Depth	Sq. Ft. of Trench Area	Trench Separation	
47	20.109	9.0	Good	Platted	18" to 24"	300 sq. ft. per bedroom	standard	None
48	20.24	11.8	Good	"	"	"	"	"
49	26.65	6.6	Good	"	"	"	"	"
50	20.11	8.1	Good	"	"	"	"	"
51	22.16	8.5	Good	"	"	"	"	"
52	23.45	9.2	Good	"	"	"	"	"
53	20.07	9.0	Good	"	"	"	"	"
54	20.07	10.4	Good	"	"	"	"	"
55	20.19	15.4	Good	"	"	"	"	"

SUBDIVISION
Approved Lots Subject to Noted Modifications

[illegible]