

INSPECTION TO BE
PRINTED OR TYPED

STATE OF WEST VIRGINIA

HARDY COUNTY HEALTH DEPARTMENTON-SITE SEWAGE DISPOSAL SYSTEM
INSPECTION FORMPermit No.: ST-16-02-111

Tax Map: _____ Parcel #: _____

County Road: _____

County: HARDY

Name of Owner: WILLIAM ECKMAN Installer: ROBERT MONGOLD
 Address: P.O. Box 7, Lost City, WV 26810
 Property Location: DELAWARE SUBDIVISION, STRAUSSMAN HOLLOW, MATIAS, WV
 Type of Facility: HOME Facility Is: New ☒ Existing () Lot Size: 10 ~~Sq.~~ Ft./Acres
 Design Loading in gpd/No. Bedrooms: 2 BDRM Source of Water Supply: WELL

SEWAGE TANK COMPONENT

Capacity in Gallons: 1000 Material: CONCRETE Manufacturer: _____
 Distances (in feet) of Tank to: Dwelling: 50' Private ☒ Public () Water Source: >80' Property Line: >10'

ON-SITE DISPOSAL SYSTEM

Class I Systems: Standard Soil Absorption Trenches () or Bed () Gravelless Pipe ☒ Diameter: 10 Inches
 Chamber Soil Absorption Trenches () or Bed ()
 Class II Systems: Pumped/Dosed Soil Absorption Trenches () or Bed () Evapotranspiration Trenches () or Bed ()
 Shallow Soil Absorption Trenches () or Bed () Other: _____

No. of Lines: 2 Length (in feet) of Each: 100, 70, _____, _____, _____
 Width of Trenches: 24 inches/feet Depth to Bottom of Field: 24-36 inches
 If Bed, Dimensions (in Feet): _____ If Chamber System, Name: _____, No. of Units: _____
 Approved and Adequate Materials Used? Yes ☒ No () Size Equates to: 510 Square Feet of Standard Gravel Field.
 Distances (in feet) of System to: Dwelling: >70' Private ☒ Public () Water Source: 100' Property Line: >10'
 Remarks: _____

An inspection indicates that the sewage disposal system described above
DOES MEET ☒,
DOES NOT MEET (),
CANNOT BE DETERMINED TO MEET () the minimum standards established by the West Virginia Bureau of Public Health.

To correct a health hazard, modifications to existing systems may be done to improve part of a system. Such modifications may not be able to be designated as a **does meet** system since inadequate information is known.

Although many factors contribute to the successful functioning of a sewage disposal system, this office recommends water conservation and maintaining an even usage of water throughout the week.

Sketch of Installation with Triangulation or Distance to Specific Landmarks:

TANK COORDINATES

38° 55' 18.462"N

78° 52' 17.688"W

WELL COORDINATES

38° 55' 18.334"N

78° 52' 17.033"W

Draw Arrow
toward North

Visit Date(s): _____

Final Inspection Date: 9-24-02Sanitarian: Lemone K. Thompson, R.S.

